

Individual homework assignment 3

“Determination of the optimal selection pressure for powering the NPP deaerator”

The condensing unit is composed of a deaerator D and two surface-type regenerative preheaters HPH-1, HPH-2 (Fig. 1). Deaerator D is connected in parallel with the preheater HPH-1 ("fork" scheme).

Main parameters of the working fluid (Table 1) for the basic mode are known.
You need:

- calculate turbine efficiency for the basic mode η_{tu} ;
- determine expenditures and particular settings for the mode with the new value of the degree of pressure reduction $k_{th} = p_1/p_D$ in reducer;
- calculate turbine efficiency for the new mode η_{tu}^{new} ;
- analyze the influence of the degree of pressure reduction k_{th} on the efficiency of steam turbine plant.




Fig. 1. Thermal scheme of a turbine plant with "fork" connection circuit of deaerator:

HPC, LPC – turbine high and low pressure cylinders; S – separator; EG – electric generator; C - condenser, CP, FP – condensate and feed pumps; HPH-1, HPH-2 – regenerative surface type heaters; D – deaerator; PR – pressure reducing device

Table 1. Source data

Indicator	Variants				
	1	2	3	4	5
Basic mode					
k	1,2				
D_0 , kg/s	200	500	700	900	500
D_1 , kg/s	3,7	8,5	12,6	14,3	7,1
D_D , kg/s	33,6	79,6	120,8	120,4	58,4
D_2 , kg/s	25,3	70,0	84,2	126,2	71,3
D_s , kg/s	27,1	46,6	72,5	70	36,6
h_0 , kJ/kg	2773	2905	2898	3004	3004
h_p , kJ/kg	2409	2535	2489	2574	2576
h'_s , kJ/kg	670	670,5	670,5	697,1	655,9
h''_s , kJ/kg	2756	2756	2756	2763	2752
h_k , kJ/kg	2160	2150	2159	2136	2157
h'_k , kJ/kg	137,8	130	137,8	130	130
h_1 , kJ/kg	2601	2740	2689	2700	2707
h'_1 , kJ/kg	945,8	941,6	941,6	858,6	814,8
h_{w1} , kJ/kg	933,9	929,4	930,3	849,3	805
h'_D , kJ/kg	902,8	899	899	820	778,2
h_2 , kJ/kg	2625	2625	2591	2588	2614
h'_2 , kJ/kg	538,1	538,1	504,7	517,6	517,6
h_{w2} , kJ/kg	526,883,	526,8	493,4	505,8	505,6
New mode					
k_{th}^{new}	1,45		1,4		1,35
Indicator	Variants				
	6	7	8	9	10
	Basic mode				
k	1,2				
D_0 , kg/s	500	700	300	800	400
D_1 , kg/s	3,3	7,4	11,5	13,8	6,8
D_D , kg/s	33,6	79,6	120,8	120,4	58,4
D_2 , kg/s	25,3	70,0	84,2	126,2	71,3
D_s , kg/s	27,1	46,6	72,5	70	36,6
h_0 , kJ/kg	2773	2905	2898	3004	3004
h_p , kJ/kg	2409	2535	2489	2574	2576
h'_s , kJ/kg	670	670,5	670,5	697,1	655,9
h''_s , kJ/kg	2756	2756	2756	2763	2752

h_k , kJ/kg	2160	2150	2159	2136	2157
h'_k , kJ/kg	137,8	130	137,8	130	130
h_l , kJ/kg	2601	2740	2689	2700	2707
h'_l , kJ/kg	945,8	941,6	941,6	858,6	814,8
h_{w1} , kJ/kg	933,9	929,4	930,3	849,3	805
h'_D , kJ/kg	902,8	899	899	820	778,2
h_2 , kJ/kg	2625	2625	2591	2588	2614
h'_2 , kJ/kg	538,1	538,1	504,7	517,6	517,6
h_{w2} , kJ/kg	526,883,	526,8	493,4	505,8	505,6
New mode					
k_{th}^{new}	1,35		1,45		1,4
Indicator	Variants				
	11	12	13	14	15
Basic mode					
k	1,2				
D_0 , kg/s	250	550	750	950	550
D_1 , kg/s	3,5	8,3	12,2	14,1	7,8
D_D , kg/s	33,6	79,6	120,8	120,4	58,4
D_2 , kg/s	25,3	70,0	84,2	126,2	71,3
D_s , kg/s	27,1	46,6	72,5	70	36,6
h_0 , kJ/kg	2773	2905	2898	3004	3004
h_p , kJ/kg	2409	2535	2489	2574	2576
h'_s , kJ/kg	670	670,5	670,5	697,1	655,9
h''_s , kJ/kg	2756	2756	2756	2763	2752
h_k , kJ/kg	2160	2150	2159	2136	2157
h'_k , kJ/kg	137,8	130	137,8	130	130
h_l , kJ/kg	2601	2740	2689	2700	2707
h'_l , kJ/kg	945,8	941,6	941,6	858,6	814,8
h_{w1} , kJ/kg	933,9	929,4	930,3	849,3	805
h'_D , kJ/kg	902,8	899	899	820	778,2
h_2 , kJ/kg	2625	2625	2591	2588	2614
h'_2 , kJ/kg	538,1	538,1	504,7	517,6	517,6
h_{w2} , kJ/kg	526,883,	526,8	493,4	505,8	505,6
New mode					
k_{th}^{new}	1,30		1,5		1,45